

RESOLUTION NO. 2018 - 112

A RESOLUTION BY THE BOARD OF COUNTY COMMISSIONERS OF ST. JOHNS COUNTY, FLORIDA, AUTHORIZING THE COUNTY ADMINISTRATOR, OR DESIGNEE, TO PIGGYBACK NJPA CONTRACT # 120617-CAT, PURCHASE A GENERATOR FOR THE ST JOHNS COUNTY COMBINED FIRE STATION 5/11, AND TO EXECUTE A PURCHASE ORDER WITH RING POWER CORPORATION FOR THE PURCHASE.

RECITALS

WHEREAS, the County seeks to purchase a C13 350kW 1800RPM, 208/120 Volt, 3-Phase, 60Hz Diesel Generator for the St. Johns County Combined Fire Station 5/11; and

WHEREAS, the required generator is available from Ring Power Corporation under the National Joint Powers Alliance (NJPA) Contract #120617-CAT, and the County seeks to piggyback the contract in order to purchase the required equipment; and

WHEREAS, the purchase of the equipment will be funded by St. Johns County; and

WHEREAS, the purchase of the equipment serves a public purpose.

NOW, THEREFORE BE IT RESOLVED BY THE BOARD OF COUNTY COMMISSIONERS OF ST. JOHNS COUNTY, FLORIDA:

Section 1. The above Recitals are incorporated by reference into the body of this Resolution and such Recitals are adopted as finds of fact.

Section 2. The County Administrator, or designee, is hereby authorized to piggyback the NJPA Contract and purchase the required generator and equipment from Ring Power Corporation.

Section 3. The County Administrator, or designee, is further authorized to execute a purchase order in the amount of \$105,903.63 for the purchase of a C13 350kW 1800RPM, 208/120 Volt, 3-Phase, 60Hz Diesel Generator from Ring Power Corporation.

Section 4. To the extent that there are typographical and/or administrative errors that do not change the tone, tenor, or concept of this Resolution, then this Resolution may be revised without subsequent approval by the Board of County Commissioners.

PASSED AND ADOPTED by the Board of County Commissioners of St. Johns County, Florida, this 17 day of April, 2018.

BOARD OF COUNTY COMMISSIONERS OF
ST. JOHNS COUNTY, FLORIDA

By: Henry Dean
Henry Dean, Chair

ATTEST: Hunter S. Conrad, Clerk
By: Tom Lutterman
Deputy Clerk

RENDITION DATE 4/19/18





**OLYMPIAN™
GENERATORS**

Your North and Central Florida Caterpillar Dealer

ST. AUGUSTINE
500 World Commerce Prkwy
St. Augustine, FL 32092
904-737-7730

TALLAHASSEE
32000 Blue Star Hwy
Midway, FL 32343
850-562-1622

OCALA
6202 N US 301/441
Ocala, FL 34475
352-732-4600

ORLANDO
9901 Ringhaver Dr.
Orlando, FL 32824
407-855-6195

TAMPA
9797 Gibsonton Dr
Riverview, FL 33569
813-671-3700

SALES

SERVICE

PARTS

LEASING

RENTALS

QUOTATION / SALES AGREEMENT / SECURITY AGREEMENT

DATE: 2/08/2018

QUOTATION NO: CWM18-033 - NJPA

CUSTOMER NAME: **St. Johns County Construction**
ADDRESS: **2416 Dobbs Road**
CITY/STATE/ZIP: **St. Augustine, FL 32086**
PHONE: **904.209.0193**
CONTACT NAME: **Phyllis Thorpe**

ESTIMATED SHIPPING LEAD TIME: **14-16 weeks from release**
SHIPPING VIA/FOB: **RPC/Jobsite**
ESTIMATED SUBMITTAL LEAD TIME: **2 Weeks from order**
JOBSITE ADDRESS: **TBD**
CITY/STATE/ZIP: **St. Augustine, FL**
PROJECT NAME: **St Johns County Combined Station**

TERMS: Full payment is due from buyer within 10 days of delivery or pickup of the equipment.

DESCRIPTION OF MATERIAL	UNIT PRICE	EXTENSION
<p>One (1) New Caterpillar C13 350kW 1800RPM Diesel Engine Generator Set, Rated Standby, 208/120Volt, 3 Phase, 60Hz, Tier 3 Equipped as Follows:</p> <ul style="list-style-type: none"> • EMCP 4.2 Control Panel • Protection System – Safety Shutoffs For: <ul style="list-style-type: none"> ○ High Water Temperature ○ Overspeed ○ Low Oil Pressure • UL2200 Listed Generator • Local Annunciator NFPA99-110 • Integrated Voltage Regulator • 1200 Amp 100% UL Rated LSI Circuit Breaker 		

Quotation Accepted By: _____ Date: _____ Tax No.: _____

Customer: _____ Salesman's Signature: CLIFF MILLS

Cliff Mills – EPG Sales NE FL

TERMS

- Payment is due in full prior to shipping equipment out of the country.
- All quoted prices are subject to change without notice. Those in effect on the date of shipment shall prevail.
- Subject to credit approval.
- Used equipment is subject to prior sale.
- A 25% restocking fee will be assessed for all canceled orders or returned materials.
- No retainage to be withheld. Ring Power Systems is an equipment supplier and is not a sub-contractor.
- No sales tax is included.
- Buyer grants to seller a security interest in all equipment as described in this agreement until such time as payment is made in full in accordance with the terms and conditions of this agreement and in accord with the seller's credit application.
- Ring Power requires a purchase order to secure this sales agreement.

DESCRIPTION OF MATERIAL	UNIT PRICE	EXTENSION
<ul style="list-style-type: none"> • Shunt Trip & Auxiliary Contact • Anti-Condensation Heater • Cooling System: <ul style="list-style-type: none"> ○ Coolant Drain Line w/Valve; Terminated on edge of base ○ Package Mounted Radiator ○ Fan and Belt Guards ○ Coolant Level Sensor ○ Thermostats and Housing, full open temperature 92 deg C (198 deg F) ○ Coolant Level Sight Gauge ○ Jacket Water Pump, Gear Driven, Centrifugal ○ Caterpillar Extended Life Coolant • Starting/Charging System <ul style="list-style-type: none"> ○ Lead Acid Battery – 1000CCA – 90 Amp Hr – 12V ○ 24V, 45 Amp Charging Alternator • Standard Air Cleaner • Fuel System <ul style="list-style-type: none"> ○ Primary Fuel Filter w/Integral Water Separator & Secondary Filter. ○ Fuel Cooler – Fuel Priming Pump ○ Flexible Fuel Lines ○ Engine Fuel Transfer Pump • Electronic Governor • 10 Amp Dual Rate Battery Charger 110VAC • Coolant Heater – Typically On At 100 and off at 120 Degree F • Caterpillar Factory Aluminum Sound Attenuated Enclosure <ul style="list-style-type: none"> ○ 150MPH Wind Load Rated 		
Total List Price For Above CAT Items		\$123,238.00
NJPA Discount – 37% Off Of List Price		(\$45,598.06)
Total List Price With NJPA Discount		\$77,639.94
<u>Sourced Good and Support Service NJPA Discount</u>		
<u>CAT Dealer Additions – All Receive 5% Off List Price per NJPA</u>		
Asco – 300 Series, Service Entrance Rated, 1200 Amp, Nema 1 Enclosure		\$12,807.50
Freight (Generator Set to Site)		\$1,950.00
Custom 24 Hour Run Time 1,800 Gallon Subbase Fuel Tank (See Below)		\$9,203.75
5 Year Platinum Plus Extended Warranty		\$1,390.00
<u>Startup and Commissioning – Generator Set</u>		<u>\$4,400.00</u>
Total List Price For Above Sourced Good And Service Items		\$29,751.25
Total List Price With NJPA Discount – 5% Off Of List Price		\$28,263.69
TOTAL NET COST FOR ABOVE		\$105,903.63
NJPA – National Joint Powers Alliance Contract #120617 - CAT St Johns County BOCC NJPA Contract Number NJPA110164		
Fidelity Manufacturing 24 Hour Run Time Fuel Tank		
<ul style="list-style-type: none"> • 1,800 Usable Gallon Capacity – 72 Hour Run Time • Subbase Fuel Tank • UL-142 Listed • Structural Tank w/Tank Top Provisions • Standard Low Fuel Level Switch Set to Alarm at 25% Fuel Capacity • Standard Leak Detection/Rupture Basin Switch • 7-1/2 Gallon Fuel Fill Spill Bucket 		

DESCRIPTION OF MATERIAL	UNIT PRICE	EXTENSION
<p>Asco 300 Series 1200 Amp Automatic Transfer Switch</p> <ul style="list-style-type: none"> • 208/120Volt 3 Phase • 4 Pole – Open Transition • Service Entrance Rated • Nema 1 Enclosure <p>Exceptions: Generator quoted with steel base as per standard factory specifications. Providing a stainless steel or aluminum base will add substantial cost to this product. This quote is based on the standard polyester powder coated steel base.</p> <p>NOTES:</p> <ol style="list-style-type: none"> 1. DIESEL FUEL IS NOT INCLUDED IN PRICE. 2. ELECTRICAL & MECHANICAL INSTALLATION NOT INCLUDED. 3. FREIGHT TO THE JOB SITE IS INCLUDED. OFFLOADING BY OTHERS. 4. <u>QUOTED PER DWG PROJECT NO 944-15 DATED 10.17.17 PAGE E-0.02.</u> 5. CURRENT PRODUCT LEAD TIME IS NOTED ABOVE IN WEEKS BUT IS SUBJECT TO CHANGE ACCORDING TO FACTORY AVAILABILITY. 6. ALL WORK BY RPC TECHNICIANS WILL BE PERFORMED DURING NORMAL WORKING HOURS. 7. FDEP & EPA NOTICES OF DELIVERY, PERMITTING, AND REGISTRATION ARE NOT INCLUDED. THIS IS THE RESPONSIBILITY OF THE INSTALLING CONTRACTOR AND/OR OWNER. 8. ONSITE LOAD BANK TESTING WILL NEED TO BE QUOTED IF REQUIRED. A SURVEY OF THE INSTALLATION LOCATIONS WILL BE NECESSARY TO PROVIDE FIRM PRICING. 9. CREDIT TERMS TO BE DETERMINED AT THE TIME OF ORDER. 		

FORM E
CONTRACT ACCEPTANCE AND AWARD



(Top portion of this form will be completed by NJPA if the vendor is awarded a contract. The vendor should complete the vendor authorized signatures as part of the RFP response.)

NJPA Contract #: 120617-CAT

Proposer's full legal name: Caterpillar Inc.

Based on NJPA's evaluation of your proposal, you have been awarded a contract. As an awarded vendor, you agree to provide the products and services contained in your proposal and to meet all of the terms and conditions set forth in this RFP, in any amendments to this RFP, and in any exceptions that are accepted by NJPA.


The effective date of the Contract will be January 29, 2018 and will expire on January 29, 2022 (no later than the later of four years from the expiration date of the currently awarded contract or four years from the date that the NJPA Chief Procurement Officer awards the Contract). This Contract may be extended for a fifth year at NJPA's discretion.

NJPA Authorized Signatures:



NJPA DIRECTOR OF COOPERATIVE CONTRACTS
AND PROCUREMENT/CPO SIGNATURE

Jeremy Schwartz
(NAME PRINTED OR TYPED)



NJPA EXECUTIVE DIRECTOR/CEO SIGNATURE

Chad Coauette
(NAME PRINTED OR TYPED)

Awarded on January 25, 2018

NJPA Contract # 120617-CAT

Vendor Authorized Signatures:

The Vendor hereby accepts this Contract award, including all accepted exceptions and amendments.

Vendor Name Caterpillar Inc.

Authorized Signatory's Title General Manager - IPSD Power Generation



VENDOR AUTHORIZED SIGNATURE

Bart Myers
(NAME PRINTED OR TYPED)

Executed on January 26, 2018

NJPA Contract # 120617-CAT